



160021343787

检 测 报 告

(Test Report)

No. MOB39ZCF20881555

委托单位
(Applicant)

深圳市海普瑞药业集团股份有限公司

受测单位
(Tested Unit)

深圳市海普瑞药业集团股份有限公司

签发日期
(Issued Date)

2020 年 08 月 05 日



声 明
Statement

1. 本报告无检验检测专用章、报告骑缝章和批准人签章无效。
This report is invalid without special seal of inspection, cross-page seal and the approver's signatures.
2. 本报告页面所使用“PONY”、“谱尼”字样为本单位的注册商标，其受《中华人民共和国商标法》保护，任何未经授权的擅自使用和仿冒、伪造、变造“PONY”、“谱尼”商标均为违法侵权行为，本单位将依法追究其法律责任。
The pattern and characters of "PONY" and "谱尼" used in this report are protected by the trademark law of the People's Republic of China. Any unauthorized usage, counterfeit, forgery and alteration of trademarks of "PONY" and "谱尼" are the violations of the law. The PONY has the right to pursue all legal liabilities of the subject of the delict.
3. 委托单位对报告数据如有异议，请于报告完成之日起十五日内（初级农产品报告请于报告收到之日起五日内）向本单位书面提出复测申请，同时附上报告原件并预付复测费。
If the applicant has any questions about the results, shall provide a written retest application with the original report, and prepay the retest fees to PONY within fifteen days since the approval date (as an exception, it shall be within five days since the date received for the primary agriculture products report).
4. 委托单位办理完毕以上手续后，本单位会尽快安排复测。如果复测结果与异议内容相符，本单位将退还委托单位的复测费。
After the applicant finishes the procedure mentioned above, PONY shall arrange the retest as soon as possible. If the retest result accords with the applicant dissent, PONY shall refund the retest fees.
5. 不可重复性或不能进行复测的实验，不进行复测，委托单位放弃异议权利。
Tests that can not be repeated and tested shall not be carried out again.
6. 委托单位对样品的代表性和资料的真实性负责，否则本单位不承担任何相关责任。
The applicant should undertake the responsibility for the provided samples' representativeness and document authenticity. Otherwise, PONY has not any relevant responsibilities.
7. 本报告仅对所测样品负责，报告数据仅反映对所测样品的评价，对于报告及所载内容的使用、使用所产生的直接或间接损失及一切法律后果，本单位不承担任何经济和法律责任。
This report is only responsible for the provided sample. The test results only represent the evaluation of the tested sample. PONY will not be responsible for any economical or legal liability generated from direct or indirect usage of the test report.
8. 本单位有权在完成报告后按规定方式处理所测样品。
PONY has the right to dispose the tested sample by rules, after approval of the test report.
9. 本单位保证工作的客观公正性，对委托单位的商业信息、技术文件等商业秘密履行保密义务。
PONY assures objectivity and impartiality of the test, and fulfills the obligation of confidentiality for applicant's commercial information, and technique document.
10. 本报告私自转让、盗用、冒用、涂改、未经本单位批准的复制（全文复制除外）或以其它任何形式的篡改均属无效，本单位将对上述行为严究其相应的法律责任。
The report is invalid in case of illegal transfer, embezzlement, imposture, modification or any altering, reproducing except in full, without approval of PONY. PONY shall investigate and affix the applicant's legal liability accordingly.

▲ 防伪说明 (Anti-counterfeiting Description) :

- (1) 报告编号是唯一的；
The test report has exclusive report code.
- (2) 报告采用特制防伪纸张印制，纸张表面带有“PONY”防伪纹路，该防伪纹路不支持复印，即复印件不会带有“PONY”防伪纹路。
The test report is printed by anti-copying paper whose surface shows "PONY" security print with specific anticounterfeiting technique. Security print will disappear after copying. Duplicates are not expected to give "PONY" security print under any circumstances.



全国服务热线
400-819-5688

WWW.PONYTEST.COM

扫描二维码
关注谱尼测试微信
公众号 PONY4008195688



北京实验室: (010) 83055000	武汉实验室: (027) 83997127	哈尔滨实验室: (0451) 58627755
上海实验室: (021) 64851999	长春实验室: (0431) 85150908	石家庄实验室: (0311) 85376660
青岛实验室: (0532) 88706866	大连实验室: (0411) 87336618	乌鲁木齐实验室: (0991) 6684186
深圳实验室: (0755) 26050909	郑州实验室: (0371) 69350670	呼和浩特实验室: (0471) 3450025
天津实验室: (022) 23607888	西安实验室: (029) 89608785	杭州实验室: (0571) 85806807
苏州实验室: (0512) 62997900	太原实验室: (0351) 7555762	宁波实验室: (0574) 87977185
		温州实验室: (0577) 88271060
		合肥实验室: (0551) 63843474
		广州实验室: (020) 89224310
		厦门实验室: (0592) 5568048
		成都实验室: (028) 87702708

检测结果 (Test Results)

No. MOB39ZCF20881555

第 1 页, 共 2 页 (page 1 of 2)

委托单位	深圳市海普瑞药业集团股份有限公司		
受测单位	深圳市海普瑞药业集团股份有限公司		
受测地址	深圳市南山区松坪朗山路 21 号		
采样日期	2020-07-29	检测日期	2020-07-29~2020-08-05
锅炉名称/型号	蒸汽锅炉/FBA-150	样品编号	F20881555
投运日期	2020.07.04	制造单位	富尔顿
锅炉容量(t/h)	—	主要燃料	天然气
排气筒名称	锅炉废气排放筒 2#	排气筒高度 (m)	11
净化设备名称/型号	—	净化方式	低氮燃烧
测点烟气温度 (℃)	153.5	烟气平均流速 (m/s)	5.4
烟气含湿量 (%)	10.1	标态干废气流量 (m ³ /h)	1.39×10 ³
检测方法	详见附表		
采样仪器	自动烟尘测试仪 等		
检测项目	检测结果		客户限值 (mg/m ³)
	排放浓度 (mg/m ³)	排放速率 (kg/h)	
氮氧化物	44	0.061	150
二氧化硫	<3	/	50
颗粒物	0.7	9.7×10 ⁻⁴	20
烟气黑度 (林格曼, 级)	<1		1

备注: “/”表示当排放浓度低于检出限时, 无需计算排放速率。





检 测 结 果 (Test Results)

No. MOB39ZCF20881555

第 2 页, 共 2 页 (page 2 of 2)

附表: 检测项目方法仪器一览表

检测项目	分析方法	方法来源	仪器设备	方法检出限
氮氧化物	定电位电解法	固定污染源废气 氮氧化物的测定 HJ 693-2014	自动烟尘测试仪	3 mg/m ³
二氧化硫	定电位电解法	固定污染源废气 二氧化硫的测定 HJ 57-2017	自动烟尘测试仪	3 mg/m ³
颗粒物	重量法	锅炉烟尘测试方法 GB/T 5468-1991	电子天平	0.1 mg/m ³
烟气黑度	测烟望远镜法	《空气和废气监测分析方法》(第四版)(增补版)	林格曼测烟望远镜	-

编制: 周海燕

审核:

谭子峰

批准:

张海萍



———以下空白———

(End of Report)

